	ATTENTION: Lens on unit will be hot allow to cool prior to removal.	Ø
	ATTENTION : On strobe beacons allow a minimum of 2 minutes for hazardous high voltage to discharge from unit.	
	ATTENTION: Disconnect from power source before installation or service to prevent electric shock.	
	ATTENTION: Installation must be carried out by an electrician in compliance with the latest codes and regulations.	(I)
		2
Dimensions in mm	Tel:+44.0)20.0743.8880 Fax:+44.0)20.0740.4200 mail:sales@it23.com web:www.a22.com	
	Mountings Panel mount Ø37mm (PG29)	Mo Pai
	B100STR115B/x 115V AC 30mA B100STR230B/x 230V AC 20mA	B1
	T = Tellow C = Clear Drder code Voltage B100STR030B/x 10-30V DC 135mA @24V DC	Or B1 138
Use Gasket	Rating: IP65 np: -25°C to +50°C t weight: 100g DC, 105g AC	IP F Uni CE
	Xenon Strobe Beacon 1J @ 0.75Hz Cable entry: Plugable 2.5mm ² terminals	1J 1J
B100STR	SPECTRA B100STR	



